



Use 3 conductor Shielded wire,
do not run
in same conduit as AC Power

PREAMPLIFIER



Turbine and Pre-amp
Installation for EZ Batch III

1963 ESSEX COURT
REDLANDS, CA 92373
(909) 307-2295 (909) 307-2395 fax

Approved By:
Drawing I.D.
Scale: none

Orig. Date: 10/14/2013
Rev. a
Rev. b

Drawn By: